ATTESTATION ◆ ATTESTATO ◆ ATESTACIÓN ◆ BESCHEINIGUNG ◆ ATTESTATION

Product Service

Attestation of Conformity

No. D6 108819 0024 Rev. 00

Holder of Attestation:	**ALP POMPA TEKNOLOJILERI TICARET SANAYI A.S.** Dudullu OSB 2.Cadde No:14 34775 Umraniye Istanbul TÜRKIYE
Product:	**Circulation pump**
Model(s):	**ECP25-12-180H, ECP25-12-180H(N)Paslanmaz**
Parameters:	Rated voltage: AC230V Rated frequency: 50/60Hz Rated input power: 350W Max. Protection class: I Degree of protection: IP44 Declared head: 12 m Max. Declared flow: 12.5 m^3/h Max. Declared EEI: ≤0.23 Implementation Measure EC Regulation No 641/2009:2009-07-22 amended by (EU) 622/2012:2012-07-11, (EU) 2016/2282:2016-11-30, (EU) 2019/1781:2019-10-01 Stage 2 (2015-08-01)
Brand Name:	**ETNA**
Tested according to:	PPP 11093E:2019 EN 16297-1:2012 EN 16297-2:2012 EN 16297-3:2012

This Attestation of Conformity is issued on a voluntary basis and confirms that the listed product fulfils the generic ecodesign requirements as stated in Annex I in combination with the specific ecodesign requirements defined in the above mentioned Implementation Measure and as stated in Annex II of Council Directive 2009/125/EC for the setting of ecodesign requirements for energy-related products. This attestation refers only to the particular sample and its technical documentation submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 871282501758-00

Date, 2025-06-26

(Lucy (Jianying) Lu)

TÜV SÜD Product Service GmbH • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®